



TC-9891

District Level Water Analysis Laboratory Aligarh  
Address: First Floor, Office of Superintending Engineer U.P. Jal Nigam (Urban)  
Aligarh 202001

**Water Test Report**

Report No:	ALI/ILC/Pv1/011	Issue Date:	18/11/2023
UTR No.	TC989123000000011A	Page No	01

**Customer Details**

Office Name and Address	M/s RADHA INTERNATIONAL ACADEMY SR. SEC. SCHOOL
Ref Letter No & Date	CBSE/AFF/17-11-2023

**Basic details of sample**

District	Aligarh	Block	Iglas
Gram Panchayat	-	Village / NPP	-
Habitation	-	Location	Radha International Academy Sr. Sec. School Gonda Road, Iglas, Aligarh (U.P.)
Water Source	Tube well	Sample No.	01
Quantity of Sample	1000 ml	Date of Collection	17/11/2023
Receiving Date	17/11/2023	Sample Collector	Mr. Deepak Sharma
Sample Depositor	Mr. Deepak Sharma	Sampling Method	As per IS 3025: Part 1:1986
Analysis Start Date	17/11/2023	Analysis Completion Date:	18/11/2023

**Technical Data of Analysis**

S No.	Analyzed parameters	Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH	-	7.32	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity	NTU	0.69	1	5	IS 3025 (Pt 10):2017
3	TDS	mg/L	109	500	2000	IS 3025 (Pt 16):2017
4	Fluoride	mg/L	0.08	1	1.5	APHA 23 <sup>rd</sup> Edition 4500-F Method C (Electrode method) 2023
5	Total Hardness	mg/L	72	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity	mg/L	56	200	600	IS 3025 (Part 23):2019
7	Chloride	mg/L	16	250	1000	IS 3025 (Part 32):2019
8	Iron	mg/L	0.01	1	1	APHA 23 <sup>rd</sup> Edition 3500-Fe Method B (Phenanthroline Method) 2023
9	Sulphate	mg/L	3.7	200	400	APHA 23 <sup>rd</sup> Edition 4500-SO4 Method E (Turbidity Method) 2023
10	Calcium	mg/L	9.6	75	200	IS 3025 (Part 40):2019
11	Magnesium	mg/L	11.7	30	100	IS 3025 (Part 46):2019
12	Nitrate	mg/L	1.4	45	45	APHA 23 <sup>rd</sup> Edition 4500-NO3 Method D (UV Screening Method) 2023
13	Arsenic	mg/L	0	0.01	0.30	IS 3025 (Part 37):2022
14	Color (Hazen)	-	1	5	15	APHA 23 <sup>rd</sup> Edition Color 2120 B (Visual Comparison Method)
15	Odour	-	Agreeable	-	-	IS 3025 (Part 05):2018
16	Taste	-	Agreeable	-	-	IS 3025 (Part 08):2022
17	E.-Coli.	CFU	0	-	-	APHA 23 <sup>rd</sup> Edition. 2017
18	Total Coliform	CFU	0	-	-	APHA 23 <sup>rd</sup> Edition. 2017



**Note**

1. This Certificate refers only to the sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of tests reports.
5. Remark- Parameters above permissible limits are written in Bold.

**Tested By-**

  
Yashwant Singh  
(Deputy Technical Manager)

**Authorized Signatory**

  
Shailendra Singh Rajawat  
(Quality/Technical Manager)  


Laboratory Contact details  
Email- waterlab.alig@gmail.com

Mob-6350499124

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2023/63/inspection

Dated: 18/11/2023

It is certified that an inspection team headed by Dr. Iskomd Raja(Name of Officers with designation) from Medical Subdt. CHC Iglas (Aligarh)(Name of Department/ Office) inspected the Radha International Academy Gonda Road Iglas (Aligarh)(Name & Address of the school) on 18/11/2023 (date of inspection) and found that theRadha International Academy (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of .....

Signature with Seal: IshorName Dr. Iskomd RajaDesignation Medical Subdt. CHC Iglas (Aligarh)Name & Address of the Officer/ Department: अधीक्षक (अलीगढ़)इगलास (अलीगढ़)

To

Radha International Academy  
Gonda Road Iglas Aligarh  
School Code- 60809  
(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.